

THE TOWN OF Batesburg-Leesville

Sanitary Sewer Overflow

FOR IMMEDIATE RELEASE

September 27, 2022

Contact: Tim Schumpert

803-532-4601 tschumpert@batesburg-leesville.org

The Town of Batesburg-Leesville Utilities Department experienced a Sanitary Sewer Overflow on September 27, 2022 at the following location:

305 South Oak Street

The overflow was released from a manhole surcharged and blocked due to grease and rags. The rags appear to be "flushable wipes". The volume of the sewage released is estimated to be approximately 9,000 gallons. Town staff cleared the line by jetting the main from manhole to manhole.

Mitigation of the leak included spreading of pelletized lime. Town staff will follow up with continued inspection and evaluation of the area. The area was marked with yard signs.

South Carolina DHEC has been notified. Town staff are continuing to monitor the situation and respond accordingly by providing reports to SCDHEC.

-###-